

WASTEWATER TREATMENT STRIP

INSTRUCTIONS FOR USE OF SPECIFICATION 635

1. APPLICABILITY

Construction Specification 635 is applicable to wastewater treatment strip.

area(s) and waste or disposal area(s), if required.

2. ITEMS TO BE INCLUDED IN SECTION 5 AND/OR DRAWINGS

- | | |
|--|---|
| <p>a. Plan view location and dimensions of wastewater treatment strip and other proposed practices.</p> | <p>d. Settling and/or pump tank requirements and locations.</p> |
| <p>b. Material requirements for dosing or sprinkler system. Include pump, sprinklers, nozzles, valves, pipes, pressure, capacities, solids handling capacity, etc.</p> | <p>e. Temporary and permanent vegetative and/or mulching requirements.</p> |
| <p>c. Locations of special borrow</p> | <p>f. Reference to other practice specifications (PA 634, PA 442, PA 382), if applicable.</p> |
| | <p>g. Erosion and sediment control.</p> |
| | <p>h. PA Utility Act compliance.</p> |